

SOUNDPROOFING, ACOUSTICS, NOISE & VIBRATION CONTROL SPECIALISTS

123 Columbia Court North • Suite 201 • Chaska, MN 55318 (952) 448-5300 • Fax (952) 448-2613 • (800) 448-0121

Email: sales@acousticalsurfaces.com
Visit our Website: www.acousticalsurfaces.com

We Identify and S.T.O.P. Your Noise Problems

PAGE: 1 OF 4

HUNTINGDON ENGINERING & ENVIRONMENTAL, INC. 662 Cromwell Avenue St. Paul, Minnesota 55114

SOUND TRANSMISSION CLASS (STC) – ASTM): E90(90)

Composite Barrier Material

Rendered by Manufacturer and Released to: Architectural Surfaces Inc./Acoustical Surfaces, Inc. 123 Columbia Court North Chaska, Minnesota 55318

Client Purchase Order Number: 60411 Huntingdon Project Number: 4140 94-1981 Date: June 29, 1994

Purchased By:

Michael S. Karcher Engineering Technician

Mechanical/Metallurgical Department

(612) 659-7326

Reviewed By:

Richard O. Thornalla Acoustical/Fenestration Supervisor Mechanical/Metallurgical Department (612) 659-7310

The test results contained in this report pertain only to the samples submitted for testing and not necessarily to all similar products.

Huntingdon



SOUNDPROOFING, ACOUSTICS, NOISE & VIBRATION CONTROL SPECIALISTS

123 Columbia Court North • Suite 201 • Chaska, MN 55318 (952) 448-5300 • Fax (952) 448-2613 • (800) 448-0121

Email: sales@acousticalsurfaces.com
Visit our Website: www.acousticalsurfaces.com

We Identify and S.T.O.P. Your Noise Problems

Huntingdon

PROJECT NUMBER: 4140 94-1981 PAGE: 2 of 4

DATE: June 29, 1994

SOUND TRANSMISSION CLASS (STC) – ASTM: E90(90)

INTRODUCTION:

This report presents the results of a Sound Transmission Class (STC) test conducted on a Composite Barrier Material submitted by the Manufacturer. This test was requested by Manufacturer on June 17, 1994 with the testing conducted on June 20, 1994.

This report must not be reproduced except in full with the approval of Huntingdon Engineering & Environmental, Inc. the data in this report relates only to the item tested.

Huntingdon has been accredited by the U.S. Department of Commerce and the National Institute of Standards and Technology (NIST, formerly NBS) under their National Voluntary Laboratory Accrediation Program (NVLAP) for conducting this test procedure. This report may not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

TEST RESULTS SUMMARY:

The STC of the specimen described below was <u>29</u>. A tabular and graphical presentation of the data is presented under "TEST RESULTS".

SPECIMEN IDENTIFICATION:

Manufacturer: Rendered by Manufacturer and Released to:

Architectural Surfaces Inc./Acoustical Surfaces Inc.

Model #: Composite Barrier Material

Nominal Dimensions (W x H x D): 4.5' x 4.5' x 1.25"

Weight: 25 lbs. (1.2 psf)

Specimen Description: - 1" Flat Foam

- Rubber Bonding Material

- 1/4" Flat Foam

AS MUTUAL PROTECTION TO CLIENTS THE PUBLIC AND OURSELVES, ALL HUNTINGDON ENGINEERING & ENVIRONMENTAL INC. REPORTS ARE SUBMITTED AS THE CONFIDENTIAL INFORMATION OF CLIENTS AND AUTHORIZATION FOR PUBLICATION OF STATEMENTS CONCLUSIONS OR EXTRACTIONS FROM OR REGARDING OUR REPORTS IS RESERVED PENDING OUR PRIOR WRITTEN APPROVAL.

A member of the HIH group of companies

Soundproofing Products • SonexTM Ceiling & Wall Panels • Sound Control Curtains • Equipment Enclosures • Acoustical Baffles & Banners • Solid Wood & Veneer Acoustical Ceiling & Wall Systems
• Professional Audio Acoustics • Vibration & Damping Control • Fire Retardant Acoustics • Hearing Protection • Moisture & Impact Resistant Products • Floor Impact Noise Reduction
• Sound Absorbers • Noise Barriers • Fabric Wrapped Wall Panels • Acoustical Foam (Egg Crate) • Acoustical Sealants & Adhesives • Outdoor Noise Control • Assistive Listening Devices
• OSHA, FDA, ADA Compliance • On-Site Acoustical Analysis • Acoustical Design & Consulting • Large Inventory • Fast Shipment • No Project too Large or Small • Major Credit Cards Accepted



SOUNDPROOFING, ACOUSTICS, NOISE & VIBRATION CONTROL SPECIALISTS

123 Columbia Court North • Suite 201 • Chaska, MN 55318 (952) 448-5300 • Fax (952) 448-2613 • (800) 448-0121

Email: sales@acousticalsurfaces.com
Visit our Website: www.acousticalsurfaces.com

We Identify and S.T.O.P. Your Noise Problems

Huntingdon

PROJECT NUMBER: 4140 94-1981 PAGE: 3 of 4

DATE: June 29, 1994

TEST EQUIPMENT:

<u>Manufacturer</u>	<u>Model</u>	<u>Description</u>	<u>S/N</u>
Northern Electronics	NE830	Real Time Analzer	
Brüel & Kjær	3923	Rotating Microphone Boom	11511
Brüel & Kjær	4132	Pressure Condenser Microphone	815424
Larson-Davis	2560	Pressure Condenser Microphone	239016

TEST RESULTS:

Freq. (Hz)	TL	CL	Def	Freq. (Hz)	TL	CL	Def
125	20	3	0	800	27	0	4
160	21	2	0	1000	28	1	4
200	19	2	0	1250	30	0	3
250	21	1	1	1600	32	0	1
315	22	1	3	2000	32	0	1
400	23	1	5	2500	34	1	0
500	25	1	4	3150	37	1	0
630	25	1	5	4000	42	1	0

TOTAL DEFICIENCIES: 31 STC: 29

Where: TL = Transmission Loss (dB)

CL = 95% Confidence Limit (db)

Def= Deficiencies (below STC contour)

AS MUTUAL PROTECTION TO CLIENTS THE PUBLIC AND OURSELVES, ALL HUNTINGDON ENGINEERING & ENVIRONMENTAL INC. REPORTS ARE SUBMITTED AS THE CONFIDENTIAL INFORMATION OF CLIENTS AND AUTHORIZATION FOR PUBLICATION OF STATEMENTS CONCLUSIONS OR EXTRACTIONS FROM OR REGARDING OUR REPORTS IS RESERVED PENDING OUR PRIOR WRITTEN APPROVAL.

A member of the \fbox{HIH} group of companies

Soundproofing Products • Sonex™ Ceiling & Wall Panels • Sound Control Curtains • Equipment Enclosures • Acoustical Baffles & Banners • Solid Wood & Veneer Acoustical Ceiling & Wall Systems • Professional Audio Acoustics • Vibration & Damping Control • Fire Retardant Acoustics • Hearing Protection • Moisture & Impact Resistant Products • Floor Impact Noise Reduction • Sound Absorbers • Noise Barriers • Fabric Wrapped Wall Panels • Acoustical Foam (Egg Crate) • Acoustical Sealants & Adhesives • Outdoor Noise Control • Assistive Listening Devices • OSHA, FDA, ADA Compliance • On-Site Acoustical Analysis • Acoustical Design & Consulting • Large Inventory • Fast Shipment • No Project too Large or Small • Major Credit Cards Accepted



SOUNDPROOFING, ACOUSTICS, NOISE & VIBRATION CONTROL SPECIALISTS

123 Columbia Court North • Suite 201 • Chaska, MN 55318 (952) 448-5300 • Fax (952) 448-2613 • (800) 448-0121

Email: sales@acousticalsurfaces.com
Visit our Website: www.acousticalsurfaces.com

We Identify and S.T.O.P. Your Noise Problems Huntingdon


PROJECT NUMBER: 4140 94-1981

PAGE: 4 of 4

DATE: June 29, 1994

TEST RESULTS (CONTINUED):

SOUND TRANSMISSION CLASS (STC) COMPOSITE BARRIER MATERIAL



TEST PROCEDURE:

ASTM:E90(90) was followed in every respect. The STC value was obtained by applying the Transmission Loss (TL) values to the STC reference contour of ASTM: E413(87). The temperature and relative humidity of the termination room during the test was 70°F and 48%, respectively. All frequencies met the requirements for 95% confidence established by the standard.

REMARKS:

The test material will be retained for thirty days from the date of this report and then discarded unless otherwise notified.

AS MUTUAL PROTECTION TO CLIENTS THE PUBLIC AND OURSELVES, ALL HUNTINGDON ENGINEERING & ENVIRONMENTAL INC. REPORTS ARE SUBMITTED AS THE CONFIDENTIAL INFORMATION OF CLIENTS AND AUTHORIZATION FOR PUBLICATION OF STATEMENTS CONCLUSIONS OR EXTRACTIONS FROM OR REGARDING OUR REPORTS IS RESERVED PENDING OUR PRIOR WRITTEN APPROVAL.

A member of the $\left|HIH\right|$ group of companies