



Acoustical Surfaces, Inc.

SOUNDPROOFING, ACOUSTICS, NOISE & VIBRATION CONTROL SPECIALISTS

123 Columbia Court North • Suite 201 • Chaska, MN 55318
 (952) 448-5300 • Fax (952) 448-2613 • (800) 448-0121

Email: sales@acousticalsurfaces.com
 Visit our Website: www.acousticalsurfaces.com

We Identify and **S.T.O.P.** Your Noise Problems

Filename

Test#8-1 PEPP

ASTM C423 – Sound Absorption

Project Folder

Client

Product

Model #

Quantity

Comment

Acoustical Surfaces

Absorption Material

1

1" PEPP, 12" spacing

Sample Size – Wt

Sample Description #

Type A Mounting

95.0 in x 95.5 in x – 0 lbs.

8 Panels – 1" PEPP Arranged in 2 x 4 Fashion : with 12" spacing between all panels :

Time Stamp

Wed. Oct. 30, 2002 – 11:32 AM


Total Sample Area

63.0 ft²

F (Hz)	Absorption Coefficient	Absorption (Sabins)*
100	0.01	0.49
125	0.04	2.65
160	0.04	2.34
200	0.05	3.39
250	0.07	4.48
315	0.10	6.16
400	0.13	8.35
500	0.20	12.85
630	0.30	18.79
800	0.50	31.67
1000	0.83	52.55
1250	1.11	69.95
1600	1.03	64.97
2000	0.81	50.86
2500	0.73	46.27
3150	0.80	50.40
4000	1.00	63.05
5000	1.06	66.56

Absorption Coefficient

Sound Absorption Coefficients



Temp (*C)

R.H. (%)

ATM (mbar)

22.0

63

990

*Total absorption based on 63.0 ft²

$$SAA = 0.49 \quad NRC = 0.50$$